UL-EU CERTIFICATE

Certificate No. UL-EU-00942

Page 1/6

Date of Issue 2016-03-22

Certificate Holder FSi Ltd

Westminster Industrial Estate

Tamworth Rd Measham DE12 7DS

United Kingdom

Manufacturer A/008

Certified Product Type Fire Stop - Pipe Collar

Product Trade Name PipeBloc PCP

Trademark N/A

Rating/Classification See Appendix

Harmonised Technical Specifications ETAG 026-2 / EN 13501-2 / EN 13501-1

Supporting Documentation ETA 15/0489, EC – CERTIFICATE OF CONSTANCY OF

PERFORMANCE - 1121 - CPR - JA5080

Additional information N/A

Expiry date 2026-03-21



Certification Manager

Chris Miles

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



Certificate No. UL-EU-00942

Page 2/6

Date of Issue 2016-03-22

This certificate relates to the use of PipeBloc PCP for fire stopping where services penetrate floors and walls. The detailed scope is given in pages 3 to 5 of this Certificate. This shows the thickness and acceptable dimensions, substrates and orientations required to provide fire resistance periods of up to 240 minutes (EI 240).

The product is certificated on the basis of:

- i) ETA 15/0489
- ii) EC CERTIFICATE OF CONSTANCY OF PERFORMANCE 1121 CPR JA5080
- ii) Inspection and surveillance of factory production control by UL
- iii) Fire resistance test data in accordance with 1366-3: 2009
- iv) Classification in accordance with EN 13501-2
- v) Classification in accordance with EN 13501-1
- vi) Durability and Servicability as defined in ETAG 026-2

The durability class of PipeBloc PCP is X - intended for use in conditions exposed to weathering (includes all lower classes).



Certificate No. UL-EU-00942

Page 3/6

Date of Issue 2016-03-22

Product-type: Pipe Collar	Intended use: Pene	tration Seal		
Basic requirement for construction work	Basic Requirement	Basic requirement for construction work		
YUi YUi YU	BWR 1 Mechanical resistance and stabili	ty		
	None			
Mir. Mir. Mir.	BWR 2 Safety in case of fire	Mil.Mil.Mi		
EN 13501-1	Reaction to fire	Class E		
EN 13501-2	Resistance to fire	See page 5		
)(U ₁)(U ₁)(U ₁	BWR 3 Hygiene, health and environmen	t)(U))(U))(U		
EN 1026:2000	Air permeability (material property)	No performance determined		
ETAG 026-3, Annex C	Water permeability (material property)	No performance determined		
Declaration of manufacturer	Release of dangerous substances	Use category IA1, S/W3 Declaration of manufacturer		
YU: YU: YU	BWR 4 Safety in use	- Y U - Y U - Y U		
EOTA TR 001:2003	Mechanical resistance and stability	No performance determined		
EOTA TR 001:2003	Resistance to impact/movement	No performance determined		
EOTA TR 001:2003 ISO 11600	Adhesion	No performance determined		
YUNYUNYU	BWR 5 Protection against noise	ny uniy uniy u		
EN 10140-2/ EN ISO 717-1	Airborne sound insulation	No performance determine		
EN 10140-3/EN ISO 717-2	Impact sound insulation	No performance determined		
A PARTY IN	SWR 6 Energy economy and heat retention	on		
EN 12664, EN 12667 or EN 12939	Thermal properties	No performance determined		
EN ISO 12572 EN 12086	Water vapour permeability	No performance determined		
人で人でし人で	General aspects relating to fitness for us	e / L / L / L		
ISO 8339: 2005, ISO 9046: 2004 & ISO 7389: 2003	Durability and serviceability	X		
В	WR 7 Sustainable use of natural resource	ees		
		No performance determined		



Certificate No. UL-EU-00942

Page 4/6

Date of Issue 2016-03-22

Substrate	Minimum Substrate Thickness (mm)	Annular space sealed with Pyrocoustic (mm)	Collar Position	Inlay W X H (mm)	Reference	Pipe	Resis	Fire esistance (mins.)				
K >=	-/.\	X	\times	30 x 4	32 mm PipeBloc PCP	32 mm Ø PVC with 1.8mm wall thickness		5				
					40 mm PipeBloc PCP	40 mm Ø PVC with 1.8mm wall thickness						
	1/				50 mm PipeBloc PCP	50 mm Ø PVC with 1.8mm wall thickness						
	1 M II v	MILLIN	$\Pi_{Y} \cdot V$	30 x 6	55 mm PipeBloc PCP	55mm Ø PVC with 2.3-3mm wall thickness						
	レクヘーレ		X	30 X 0	63 mm PipeBloc PCP	63mm Ø PVC with 2.3-3mm wall thickness						
				30 x 8	75 mm PipeBloc PCP	75mm Ø PVC with 3.1-4.8mm wall thickness						
					82 mm PipeBloc PCP	82mm Ø PVC with 3.1-4.8mm wall thickness	$\langle \rangle$					
	. \/11.	MIL M		11. \	90 mm PipeBloc PCP	90mm Ø PVC with 4.2-7.4mm wall thickness						
		H UI H	ULIL	30 x 10	100 mm PipeBloc PCP	100mm Ø PVC with 4.2-7.4mm wall thickness						
			\times	/ ^	110 mm PipeBloc PCP	110mm Ø PVC with 4.2-7.4mm wall thickness						
				40 x 12	125 mm PipeBloc PCP	125mm Ø PVC with 6.0mm wall thickness						
	1/11	100		40 x 16	140 mm PipeBloc PCP	140mm Ø PVC with 6.1-7.5mm wall thickness						
	- W III	M Hr W	11 t ' W	40 x 18	160 mm PipeBloc PCP	160mm Ø PVC with 6.2-9.5mm wall thickness		1 1				
	レハーレ	U)(U)(30 x 4	32 mm PipeBloc PCP	32 mm Ø PP with 2.9mm wall thickness		120*				
					40 mm PipeBloc PCP	40 mm Ø PP with 2.9mm wall thickness						
Drywall/ Masonry/ Concrete					50 mm PipeBloc PCP	50 mm Ø PP with 2.9mm wall thickness						
	· \/'11:			30 x 6	55 mm PipeBloc PCP	55mm Ø PP with 2.9-4.4mm wall thickness	120*					
					63 mm PipeBloc PCP	63mm Ø PP with 2.9-4.4mm wall thickness						
	-// -			30 x 8	75 mm PipeBloc PCP	75mm Ø PP with 2.8-6.7mm wall thickness						
					82 mm PipeBloc PCP	82mm Ø PP with 2.8-6.7mm wall thickness						
		1	Both sides		90 mm PipeBloc PCP	90mm Ø PP with 2.7-10mm wall thickness						
wall	100	100 10		30 x 10	100 mm PipeBloc PCP	100mm Ø PP with 2.7-10mm wall thickness						
レハビレハ					110 mm PipeBloc PCP	110mm Ø PP with 2.7-10mm wall thickness						
				40 x 12	125 mm PipeBloc PCP	125mm Ø PP with 3.1mm wall thickness						
				40 x 16	140 mm PipeBloc PCP	140mm Ø PP with 3.5-8.0mm wall thickness						
	\/II.	V/11.37/	11. \/	40 x 18	160 mm PipeBloc PCP	160mm Ø PP with 4.0-14.5mm wall thickness						
	100 131		y	40 X 10	32 mm PipeBloc PCP	32 mm Ø PE with 2.9mm wall thickness	3	Y				
	h / N hr			30 x 4	40 mm PipeBloc PCP	40 mm Ø PE with 2.9mm wall thickness						
					50 mm PipeBloc PCP	50 mm Ø PE with 2.9mm wall thickness						
	1/2				55 mm PipeBloc PCP	55mm Ø PE with 2.9-4.4mm wall thickness						
)(UL)(UL)(30 x 6	63 mm PipeBloc PCP	63mm Ø PE with 2.9-4.4mm wall thickness	LU.	J)					
			Y 1. //	75 mm PipeBloc PCP	75mm Ø PE with 2.8-6.7mm wall thickness							
			30 x 8	82 mm PipeBloc PCP	82mm Ø PE with 2.8-6.7mm wall thickness							
		YOU	ūχ		90 mm PipeBloc PCP	90mm Ø PE with 2.7-10mm wall thickness		D				
	3/11-3			30 x 10	100 mm PipeBloc PCP	100mm Ø PE with 2.7-10mm wall thickness						
					110 mm PipeBloc PCP	110mm Ø PE with 2.7-10mm wall thickness						
	-/\ L.	// L//	- L/	40 x 12	125 mm PipeBloc PCP	125mm Ø PE with 3.1mm wall thickness						
		$\times \times \times$	K	40 x 12 40 x 16	140 mm PipeBloc PCP	140mm Ø PE with 3.1mm wall thickness						
				40 x 16 40 x 18	160 mm PipeBloc PCP	140mm Ø PE with 3.9-5.8mm wall thickness 160mm Ø PE with 4.9-9.5mm wall thickness						
M	- WIII-	WILL W		40 x 18 30 x 10				_				
Masonry/	$-N \sim L$	$\Lambda \cup L \Lambda$		$\Lambda^{U}L\Lambda$	$M \sim L M$	$M \sim L M$	$N^{\nu}LN$		110 mm PipeBloc PCP	110mm Ø PP with 2.7mm wall thickness	120~	120~
Concrete	1 \				160 mm PipeBloc PCP	160mm Ø PP with 4.0mm wall thickness	120*	120*				
wall				40 x 24	250 mm PipeBloc PCP	250mm Ø PP with 6.2mm wall thickness	120*	120				

^{*} Uncapped/Capped (U/C)



[~]Uncapped/Uncapped (U/U)

Certificate No. UL-EU-00942

Page 5/6

Date of Issue 2016-03-22

Substrate	Minimum Substrate Thickness (mm)	Annular space sealed with Pyrocoustic	Collar Position	Inlay W X H (mm)	Reference	Pipe	Resis	Fire Resistance (mins.) E EI	
526		(mm)		30 x 4	32 mm PipeBloc PCP	32 mm Ø PVC with 1.8mm wall thickness	Q	240*	
					40 mm PipeBloc PCP	40 mm Ø PVC with 1.8mm wall thickness			
					50 mm PipeBloc PCP	50 mm Ø PVC with 1.8mm wall thickness			
		M UL M		30 x 6	55 mm PipeBloc PCP	55mm Ø PVC with 2.3-3mm wall thickness			
シハ・シハ					63 mm PipeBloc PCP	63mm Ø PVC with 2.3-3mm wall thickness			
		1			75 mm PipeBloc PCP	75mm Ø PVC with 3.1-4.8mm wall thickness			
	1/55			30 x 8	82 mm PipeBloc PCP	82mm Ø PVC with 3.1-4.8mm wall thickness			
	i Wun	$M \cdot U + M$			90 mm PipeBloc PCP	90mm Ø PVC with 4.2-7.4mm wall thickness	W-LU		
	レハーレ	Y		30 x 10	100 mm PipeBloc PCP	100mm Ø PVC with 4.2-7.4mm wall thickness	70.7		
					110 mm PipeBloc PCP	110mm Ø PVC with 4.2-7.4mm wall thickness	100		
				40 x 12	125 mm PipeBloc PCP	125mm Ø PVC with 6.0mm wall thickness	100		
	: WII.	Will-W	11. V	40 x 16	140 mm PipeBloc PCP	140mm Ø PVC with 6.1-7.5mm wall thickness			
	レルベレ	ハッヒハ	Soffit	40 x 18	160 mm PipeBloc PCP	160mm Ø PVC with 6.2-9.5mm wall thickness			
					32 mm PipeBloc PCP	32 mm Ø PP with 2.9mm wall thickness			
				30 x 4	40 mm PipeBloc PCP	40 mm Ø PP with 2.9mm wall thickness			
	\/ii				50 mm PipeBloc PCP	50 mm Ø PP with 2.9mm wall thickness	1/11		
	1 X U1	IX U1 1X			55 mm PipeBloc PCP	55mm Ø PP with 2.9-4.4mm wall thickness	$^{\rm H}$ U		
Concrete floor 150	-/\	50 10 (to top face of floor)		30 x 6	63 mm PipeBloc PCP	63mm Ø PP with 2.9-4.4mm wall thickness	240*		
				30 x 8	75 mm PipeBloc PCP	75mm Ø PP with 2.8-6.7mm wall thickness			
	150				82 mm PipeBloc PCP	82mm Ø PP with 2.8-6.7mm wall thickness			
				30 x 10	90 mm PipeBloc PCP	90mm Ø PP with 2.7-10mm wall thickness			
					100 mm PipeBloc PCP	100mm Ø PP with 2.7-10mm wall thickness			
					110 mm PipeBloc PCP	110mm Ø PP with 2.7-10mm wall thickness			
				40 x 12	125 mm PipeBloc PCP	125mm Ø PP with 3.1mm wall thickness			
	A/11.			40 x 16	140 mm PipeBloc PCP	140mm Ø PP with 3.5-8.0mm wall thickness			
	1 K U I			40 x 18	160 mm PipeBloc PCP	160mm Ø PP with 4.0-14.6mm wall thickness			
	5/ N. 15			30 x 4	32 mm PipeBloc PCP	32 mm Ø PE with 2.9mm wall thickness			
					40 mm PipeBloc PCP	40 mm Ø PE with 2.9mm wall thickness			
	1/51				50 mm PipeBloc PCP	50 mm Ø PE with 2.9mm wall thickness			
	: W III			30 x 6	55 mm PipeBloc PCP	55mm Ø PE with 2.9-4.4mm wall thickness			
	レハーレ				63 mm PipeBloc PCP	63mm Ø PE with 2.9-4.4mm wall thickness			
				30 x 8	75 mm PipeBloc PCP	75mm Ø PE with 2.8-6.7mm wall thickness			
					82 mm PipeBloc PCP	82mm Ø PE with 2.8-6.7mm wall thickness			
	. WII.			30 x 10	90 mm PipeBloc PCP	90mm Ø PE with 2.7-10mm wall thickness			
					100 mm PipeBloc PCP	100mm Ø PE with 2.7-10mm wall thickness			
					110 mm PipeBloc PCP	110mm Ø PE with 2.7-10mm wall thickness			
				40 x 12	125 mm PipeBloc PCP	125mm Ø PE with 3.1mm wall thickness			
	1/11	1/11/3/		40 x 16	140 mm PipeBloc PCP	140mm Ø PE with 3.9-5.8mm wall thickness			
	I W III	M Un W		40 x 18	160 mm PipeBloc PCP	160mm Ø PE with 4.9-9.5mm wall thickness			
	レハーレ	10 (to both	Both	30 x 10	110 mm PipeBloc PCP	110mm Ø PP with 2.7mm wall thickness	120~	120~	
		faces)	faces	40 x 16	160 mm PipeBloc PCP	160mm Ø PP with 4.0mm wall thickness	120*	120*	

^{*} Uncapped/Capped (U/C)



[~]Uncapped/Uncapped (U/U)

Appendix UL-EU Certificate

Certification Mark UL-EU mark
Certificate No. UL-EU-00942

Page 6/6

Date of Issue 2016-03-22

The UL-EU Mark, as displayed below, shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number are also required on that same label or nameplate. If cast, stamped or molded, the Certificate Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at www.ul.com.

